



JETTY CREEK DIVERSION AND STREAM RESTORATION IMPROVEMENTS PROJECT

Addendum No. 2

February 9, 2017

The following updates, clarifications and additions are hereby made a part of the Contract Documents for the Jetty Creek Diversion and Stream Restoration Improvements Project as fully and completely as if the same were fully set forth herein and must be acknowledged in the Proposal. Addendum must be acknowledged in the Proposal by the Contractor.

REMOVE

1. **Impoundment Liner:** All references to a textured impoundment liner should be removed. It should be smooth on both sides.
2. **Section 01500 paragraph 4.01A.1:** delete the words " & Traffic Safety", "traffic controls"
3. **Section 01560 paragraph 4.01A.1:** delete the words "under care and diversion of water"

CLARIFICATIONS

1. **Impoundment Liner:** The detail "SEAM PREPARATION FOR EXTRUCTION WELD" on sheet 4 is intended for repair areas, and those areas that are tested.

The anchor bar to attach to proposed retaining wall and existing intake sump wall should be extended to properly secure the liner to the dam. The connection of liner to the dam should be designed for underwater use as there will possibly be times when water spills over the dam.

2. The proposal form is referred to in the technical specifications as the bid schedule.

REPLACE

1. **Section 02220 Paragraph 4.01A** replace the first sentence with: "Measurement and payment for Demolition & Site Preparation shall be included within the lump sum bid item for Site Preparation as stated on the Bid Schedule."
2. **Section 02720 Paragraph 4.01A** replace paragraph with: "Measurement and payment for aggregate base shall be calculated as a finished in place volume as determined from the CAD file. This amount is shown on the Bid Schedule unless change orders cause a design change requiring a different amount of aggregate."

ADDITIONS

1. **Section 02300** add the following paragraph: 4.01A.b. "Excavation will be paid for by cubic yards in bank as determined from the CAD file. This amount is shown on the Bid Schedule unless change orders cause a design change requiring a different amount of excavation."

I acknowledge I have received Addendum No. 2 for the Jetty Creek Diversion and Stream Restoration Improvements Project.

Signature of contractor/authorized representative

Date