



JETTY CREEK DIVERSION AND STREAM RESTORATION IMPROVEMENTS PROJECT

Addendum No. 3

February 10, 2017

The following updates, clarifications and additions are hereby made a part of the Contract Documents for the Jetty Creek Diversion and Stream Restoration Improvements Project as fully and completely as if the same were fully set forth herein and must be acknowledged in the Proposal. Addendum must be acknowledged in the Proposal by the Contractor.

CLARIFICATIONS

1. The material of the temporary intake is shown as two pipe materials in different locations on the plans. It should be C900 PVC.
2. The configuration of the intake screen should be as shown in the details on page 12, and not as the plan view shows on page 4.
3. If the contractor needs to schedule a plant shut-down, s/he will coordinate with Luke Shepard with the City of Rockaway Beach at least a week in advance. Shutdowns shall not occur during times of peak usage.
4. The retaining wall should be 5 ft. tall in all locations. There is also a datum issue with the written elevations of the wall and the contours; the retaining wall needs to be connected at the bottom to future ground elevations.
5. A question was asked if the temporary pump could run continuously. Part of the project is to install an overflow to the plant intake wetwell. The temporary pump should only be run when needed. If it runs more, it might make the City use more than its allocated water rights.
6. Please call Luke Shepard with the City of Rockaway Beach for specific questions about the temporary pump specifications. (503)355-2982

ADDENDUM

1. Item 19 on the bid form should now read "Install two 3-inch electrical conduits and 1-inch raw water line in the same trench." The electrical and controls need to be redesigned, so this will be negotiated with the selected contractor as a change order, so do not include those items in the

bids. The 1" raw water pipe is not shown on the plans, but now should be included. The raw water pipe is for the turbidimeter.

2. Remove item 7 from the proposal form for compaction testing. No additional payment will be given for this item. Compaction testing shall be performed under the conditions outlined in the contract documents.

I acknowledge I have received Addendum No. 3 for the Jetty Creek Diversion and Stream Restoration Improvements Project.

Signature of contractor/authorized representative

Date